

VOC Content Test Certificate

Tuesday October 20th, 2009

Supplier: Blue Circle Southern Cement (Clunies Ross Street, Prospect NSW 2148)

Sample Description: Brickies Mortar

Date Tested: October 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Brickies Mortar

5 grams per Litre as VOC content of material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0909-42